

Page 1 of 32
Permit No.: WA-002099-1
Issuance Date: July 11, 2002
Effective Date: August 1, 2002
Expiration Date: July 31, 2007

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
WASTE DISCHARGE PERMIT NO. WA-002099-1

STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY
YAKIMA, WASHINGTON 98902

In compliance with the provisions of
The State of Washington Water Pollution Control Law
Chapter 90.48 Revised Code of Washington
and
The Federal Water Pollution Control Act
(The Clean Water Act)
Title 33 United States Code, Section 1251 et seq.

CITY OF SUNNYSIDE
PUBLICLY-OWNED TREATMENT WORKS
818 E. EDISON AVENUE
SUNNYSIDE, WA 98944

is authorized to discharge in accordance with the special and general conditions that follow.

<u>Plant Location:</u> 1338 S. 4 th Street Sunnyside, WA 98944	<u>Receiving Water:</u> Joint Drain 33.4, tributary to Sulphur Creek
<u>Water Body I.D. No.:</u> WA-37-1030 (Sulphur Creek Wasteway)	<u>Discharge Location:</u> Latitude: 46° 18' 50" N Longitude: 120° 00' 58" W
<u>Plant Type:</u> Class III: Trickling filter, with clarification, chlorination, and anaerobic digestion.	

G. Thomas Tebb
Section Manager
Water Quality Program
Central Regional Office
Washington State Department of Ecology

TABLE OF CONTENTS

	<u>Page</u>
SUMMARY OF PERMIT REPORT SUBMITTALS	5
SPECIAL CONDITIONS.....	6
S1. DISCHARGE LIMITATIONS	6
A. Effluent Limitations	6
B. Mixing Zone Descriptions	7
S2. MONITORING REQUIREMENTS	9
A. Monitoring Schedule	9
B. Sampling and Analytical Procedures	10
C. Flow Measurement	11
D. Laboratory Accreditation	11
E. Request for Reduction of Monitoring	11
S3. REPORTING AND RECORDKEEPING REQUIREMENTS	11
A. Reporting	12
B. Records Retention	12
C. Recording of Results	13
D. Additional Monitoring by the Permittee	13
E. Noncompliance Notification	13
S4. FACILITY LOADING	14
A. Design Criteria	14
B. Plans for Maintaining Adequate Capacity.....	14
C. Duty to Mitigate	15
D. Notification of New or Altered Sources.....	15
E. Infiltration and Inflow Evaluation	15
F. Wasteload Assessment	16
S5. OPERATION AND MAINTENANCE	16
A. Certified Operator.....	16
B. O & M Program.....	16
C. Short-term Reduction	17
D. Electrical Power Failure	17
E. Prevent Connection of Inflow	17
F. Bypass Procedures.....	17
G. Operations and Maintenance Manual.....	19
S6. PRETREATMENT	20

A. General Requirements	20
B. Wastewater Discharge Permit Required.....	20
C. Identification and Reporting of Existing, New, and Proposed Industrial Users	20
D. Duty to Enforce Discharge Prohibitions	21
S7. RESIDUAL SOLIDS	22
S8. FACILITY PLAN	22
A. Final Facility Plan Submittal	22
B. Application for Project Funding	23
C. Plans and Specifications	23
D. Application for Construction Funding	23
E. Status Report	23
F. Construction Quality Assurance Plan.....	23
S9. SCHEDULE OF COMPLIANCE	23
GENERAL CONDITIONS.....	25
G1. SIGNATORY REQUIREMENTS	25
G2. RIGHT OF INSPECTION AND ENTRY	26
G3. PERMIT ACTIONS	26
G4. REPORTING A CAUSE FOR MODIFICATION	27
G5. PLAN REVIEW REQUIRED.....	28
G6. COMPLIANCE WITH OTHER LAWS AND STATUTES	28
G7. DUTY TO REAPPLY	28
G8. TRANSFER OF THIS PERMIT.....	28
G9. REDUCED PRODUCTION FOR COMPLIANCE	29
G10. REMOVED SUBSTANCES	29
G11. DUTY TO PROVIDE INFORMATION	29
G12. OTHER REQUIREMENTS OF 40 CFR.....	29
G13. ADDITIONAL MONITORING.....	29

G14.	PAYMENT OF FEES.....	29
G15.	PENALTIES FOR VIOLATING PERMIT CONDITIONS.....	30
G16.	UPSET.....	30
G17.	PROPERTY RIGHTS.....	31
G18.	DUTY TO COMPLY	31
G19.	TOXIC POLLUTANTS.....	31
G20.	PENALTIES FOR TAMPERING.....	31
G21.	REPORTING PLANNED CHANGES	31
G22.	REPORTING ANTICIPATED NON-COMPLIANCE	32
G23.	REPORTING OTHER INFORMATION	32
G24.	COMPLIANCE SCHEDULES	32

SUMMARY OF PERMIT REPORT SUBMITTALS

Refer to the Special and General Conditions of this permit for additional submittal requirements.

Permit Section	Submittal	Frequency	First Submittal Date
S2.E.	Request for Reduction of Monitoring	As necessary	As necessary
S3.	Discharge Monitoring Report	Monthly	September 15, 2002
S3.E.	Noncompliance Notification	As necessary	As necessary
S4.B.	Plans for Maintaining Adequate Capacity	As necessary	As necessary
S4.C.	Notification of New or Altered Sources	As necessary	As necessary
S4.D.	Infiltration and Inflow Evaluation	1/permit cycle	July 31, 2006 ^a
S4.E.	Wasteload Assessment	1/permit cycle	July 31, 2006 ^a
S5.G.	Operations and Maintenance Manual	1/permit cycle	July 31, 2006 ^a
S8.A.	Final Facility Plan	1/permit cycle	April 15, 2003
S8.B.	Application for Project Funding	1/permit cycle	April 15, 2004
S8.C.	Facility Plan-Plans and Specs	1/permit cycle	January 15, 2005
S8.D.	Application for Construction Funding	1/permit cycle	April 15, 2006
S8.E.	Status Report	1/permit cycle	April 15, 2006
S8.F.	Facility Plan-Construction QA Plan	1/permit cycle	To be determined
S9.	Schedule of Compliance	1/permit cycle	April 15, 2007
G1.	Notice of Change in Authorization	As necessary	As necessary
G4.	Permit Application for Substantive Changes to the Discharge	As necessary	As necessary
G5.	Engineering Report for Construction or Modification Activities	As necessary	As necessary
G7.	Application for Permit Renewal	1/permit cycle	July 31, 2006 ^b
G21.	Notice of Planned Changes	As necessary	As necessary
G22.	Reporting Anticipated Non-compliance	As necessary	As necessary

^a With the application for permit renewal

^b At least one (1) year prior to permit expiration

THIS PAGE REVISED ON MARCH 25, 2003

SPECIAL CONDITIONS

S1. DISCHARGE LIMITATIONS

A. Effluent Limitations

1. Interim Limitations

All discharges and activities authorized by this permit shall be consistent with the terms and conditions of this permit. The discharge of any of the following pollutants more frequently than, or at a level in excess of, that identified and authorized by this permit shall constitute a violation of the terms and conditions of this permit.

Beginning on **August 1, 2002** and lasting through **April 15, 2007**, the Permittee is authorized to discharge treated municipal wastewater at the permitted location subject to complying with the following limitations:

EFFLUENT LIMITATIONS^a: OUTFALL # 001		
Parameter	Average Monthly	Average Weekly
Biochemical Oxygen Demand ^b (5 day) (BOD ₅)	30 mg/L; 540 lbs/day	45 mg/L; 811 lbs/day
Total Suspended Solids ^b (TSS)	30 mg/L; 540 lbs/day	45 mg/L; 811 lbs/day
Fecal Coliform Bacteria	200/100 mL	400/100 mL
pH	Daily minimum is equal to or greater than 6 and the daily maximum is less than or equal to 9.	
Parameter	Average Monthly	Maximum Daily^c
Total Residual Chlorine	Not Applicable	0.5 mg/L
Total Ammonia, as N (NH ₃ -N)	Not Applicable	29.7 mg/L
Parameter	Average Monthly	Minimum Daily^d
Dissolved Oxygen	Not Applicable	2.0 mg/L
a-The average monthly and weekly effluent limitations are based on the arithmetic mean of the samples taken with the exception of fecal coliform, which is based on the geometric mean.		
b-The average monthly effluent concentration for BOD ₅ and Total Suspended Solids shall not exceed 30 mg/L or 15 percent of the respective monthly average influent concentrations, whichever is more stringent.		
c-The maximum daily effluent limitation is defined as the highest allowable daily discharge. The daily discharge means the discharge of a pollutant measured during a calendar day. For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For other units of measurement, the daily discharge is the average measurement		
of the pollutant over the day.		
d-The minimum daily effluent limitation is defined as the lowest allowable daily discharge concentration.		

The daily discharge means the discharge of a pollutant measured during a calendar day. For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For other units of measurement, the daily discharge is the average measurement of the pollutant over the day.

2. Final Limitations

All discharges and activities authorized by this permit shall be consistent with the terms and conditions of this permit. The discharge of any of the following pollutants more frequently than, or at a level in excess of, that identified and authorized by this permit shall constitute a violation of the terms and conditions of this permit.

Beginning on **April 16, 2007**, and lasting through **July 31, 2007**, the Permittee is authorized to discharge treated municipal wastewater at the permitted location subject to complying with the following limitations:

EFFLUENT LIMITATIONS^a: OUTFALL # 001		
Parameter	Average Monthly	Average Weekly
BOD ₅ ^b	30 mg/L; 450 lbs/day	30 mg/L; 675 lbs/day
TSS ^b	30 mg/L; 450 lbs/day	30 mg/L; 675 lbs/day
Fecal Coliform Bacteria	100/100 MI	200/100 mL
pH	Daily minimum is equal to or greater than 6 and the daily maximum is less than or equal to 9.	
Total Residual Chlorine	Not Applicable	Not Applicable
Total Ammonia, N (NH ₃ -N)	1.1 mg/L; 16.5 lbs/day	Not Applicable
Parameter	Average Monthly	Minimum Daily^c
DO	Not Applicable	4.0 mg/L
a-The average monthly and weekly effluent limitations are based on the arithmetic mean of the samples taken with the exception of fecal coliform, which is based on the geometric mean.		
b-The average monthly effluent concentration for BOD ₅ and Total Suspended Solids shall not exceed 30 mg/L or 15 percent of the respective monthly average influent concentrations, whichever is more stringent.		
c-The minimum daily effluent limitation is defined as the lowest allowable daily discharge concentration. The daily discharge means the discharge of a pollutant measured during a calendar day. For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For other units of measurement, the daily discharge is the average measurement of the pollutant over the day.		

THIS PAGE REVISED ON

B. Mixing Zone Descriptions

The Permittee's discharge shall not be authorized a mixing zone until a mixing zone study which establishes appropriate dilution factors has been approved by the Department.

S2. MONITORING REQUIREMENTS

A. Monitoring Schedule

Parameter	Units	Sample Point	Minimum Sampling Frequency	Sample Type
BOD ₅	mg/L	Influent ^a	3/week ^b	24-hour Composite ^c
BOD ₅	lbs/day	Influent	3/week	Calculation ^d
TSS	mg/L	Influent	3/week	24-hour Composite
TSS	lbs/day	Influent	3/week	Calculation
TKN	mg/L	Influent	1/month ^e	24-hour Composite
TKN	lbs/day	Influent	1/month	Calculation
Flow	MGD	Final Effluent ^f	Continuous ^g	Metered
BOD ₅	mg/L	Final Effluent ^h	3/week	24-hour Composite
BOD ₅	lbs/day	Final Effluent	3/week	Calculation
BOD ₅	% removal	Final Effluent	1/month	Calculation
TSS	mg/L	Final Effluent	3/week	24-hour Composite
TSS	lbs/day	Final Effluent	3/week	Calculation
TSS	% removal	Final Effluent	1/month	Calculation
Fecal Coliform Bacteria	#colonies/100 mL	Final Effluent	3/week ⁱ	Grab ^j
TRC ^k	mg/L	Final Effluent	5/week	Grab
TRC	lbs/day	Final Effluent	5/week	Calculation
NH ₃ , as N	mg/L	Final Effluent	2/month ^l	Grab
NH ₃ , as N	lbs/day	Final Effluent	2/month	Calculation
DO	mg/L	Final Effluent	5/week	Grab
Temperature	°C	Final Effluent	5/week	Grab
pH	Standard Units	Final Effluent	5/week	Grab
Total Hardness	mg/L, as CaCO ₃	Final Effluent	2/month	Grab
Alkalinity	mg/L, as CaCO ₃	Final Effluent	2/month	Grab
a-"Wastewater Influent" means the raw sewage flow and shall be sampled entering the headworks of the treatment plant excluding any sidestream returns from inside the plant.				
b-"3/week" means three (3) times during each calendar week and on a rotational basis throughout				

the days of the week, except weekends and holidays.
c-"24-hour composite" means a series of individual samples collected over a 24-hour period into a single container, and analyzed as one sample.
d-"Calculation" means figured concurrently with the respective sample, using the following formula: Concentration (in mg/L) X Flow (in MGD) X Conversion Factor (8.34) = lbs/day.
e-"Monthly" means once every calendar month during alternate weeks.
f-"Final Effluent" means wastewater which is exiting, or has exited, the last treatment process or operation. Typically, this is after or at the exit from the chlorine contact chamber or other disinfection process.
g-"Continuous" means without interruption throughout the operating and discharging hours of the Permittee's facility, except for infrequent shutdowns for maintenance.
h-Effluent samples for BOD ₅ analysis may be taken before or after the disinfection process. If taken after, the sample shall be dechlorinated and reseeded.
i-Shall be sampled concurrently with Total Residual Chlorine.
j-"Grab" means an individual sample collected over a fifteen (15) minute, or less, period.
k-Sampling shall not occur when ultraviolet light (UV) disinfection system is in operation.
l-"2/month" means twice per calendar month. Samples shall not be taken during the same week nor during consecutive weeks.

B. Sampling and Analytical Procedures

Samples and measurements taken to meet the requirements of this permit shall be representative of the volume and nature of the monitored parameters, including representative sampling of any unusual discharge or discharge condition, including bypasses, upsets and maintenance-related conditions affecting effluent quality.

Sampling and analytical methods used to meet the monitoring requirements specified in this permit shall conform to the latest revision of the *Guidelines Establishing Test Procedures for the Analysis of Pollutants* contained in 40 CFR Part 136 or to the latest revision of *Standard Methods for the Examination of Water and Wastewater* (APHA), unless otherwise specified in this permit or approved in writing by the Department of Ecology (Department).

C. Flow Measurement

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the quantity of monitored flows. The devices shall be installed, calibrated, and maintained to ensure that the accuracy of the measurements are consistent with the accepted industry standard for that type of device. Frequency of calibration shall be in conformance with manufacturer's recommendations. Calibration records shall be maintained for at least three years.

D. Laboratory Accreditation

All monitoring data required by the Department shall be prepared by a laboratory registered or accredited under the provisions of, *Accreditation of Environmental Laboratories*, Chapter 173-50 WAC. Flow, temperature, settleable solids, conductivity, pH, and internal process control parameters are exempt from this requirement. Conductivity and pH shall be accredited if the laboratory must otherwise be registered or accredited.

E. Request for Reduction of Monitoring

The Permittee may request a reduction of the sampling frequency after twelve (12) months of monitoring. The request shall: (1) be in written form, (2) clearly state the parameters for which the reduction in monitoring is being requested, and (3) clearly state the justification for the reduction. Any request for reduction in monitoring shall be granted at the Department of Ecology's (Department) discretion and accomplished through an Administrative Order or permit modification.

S3. REPORTING AND RECORDKEEPING REQUIREMENTS

The Permittee shall monitor and report in accordance with the following conditions. The falsification of information submitted to the Department shall constitute a violation of the terms and conditions of this permit.

A. Reporting

The first monitoring period begins on **August 1, 2002**. Monitoring results shall be submitted monthly. Monitoring data obtained during each monitoring period shall be summarized, reported, and submitted on a Discharge Monitoring Report (DMR) form provided, or otherwise approved, by the Department. DMR forms shall be received by the Department no later than the 15th day of the month following the completed monitoring period, unless otherwise specified in this permit. Priority pollutant analysis data shall be submitted no later than forty-five (45) days following the monitoring period. The report(s) shall be sent to:

Permit Data Systems Manager
Department of Ecology
Central Regional Office
15 West Yakima Avenue, Suite 200
Yakima, Washington 98902

All laboratory reports providing data for organic and metal parameters shall include the following information: sampling date, sample location, date of analysis, parameter name, CAS number, analytical method/ number, method detection limit (MDL), laboratory practical quantitation limit (PQL), reporting units, and concentration detected.

DMR forms must be submitted monthly whether or not the facility was discharging. If there was no discharge during a given monitoring period, submit the form as required with the words "no discharge" entered in place of the monitoring results.

In addition to the monthly DMR, a monthly summary report form (EPA No. 3320-1) shall be received no later than the 15th day of the following month. This report is limited to the parameters specified in Special Condition S1.A.

B. Records Retention

The Permittee shall retain records of all monitoring information for a minimum of three (3) years. Such information shall include all calibration and maintenance records and all original recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit. This period of retention shall be extended during the course of any unresolved litigation regarding the discharge of pollutants by the Permittee or when requested by the Department.

C. Recording of Results

For each measurement or sample taken, the Permittee shall record the following information: (1) the date, exact place, method, and time of sampling or measurement; (2) the individual who performed the sampling or measurement; (3) the dates the analyses were performed; (4) the individual who performed the analyses; (5) the analytical techniques or methods used; and (6) the results of all analyses.

D. Additional Monitoring by the Permittee

If the Permittee monitors any pollutant more frequently than required by this permit using test procedures specified by Special Condition S2 of this permit, then the results of such monitoring shall be included in the calculation and reporting of the data submitted in the Permittee's DMR.

E. Noncompliance Notification

In the event the Permittee is unable to comply with any of the terms and conditions of this permit due to any cause, the Permittee shall:

1. Immediately take action to stop, contain, and cleanup unauthorized discharges or otherwise stop the noncompliance, correct the problem and, if applicable, repeat sampling and analysis of any noncompliance immediately and submit the results to the Department within thirty (30) days after becoming aware of the violation.
2. Immediately notify the Department of the failure to comply.
3. Submit a detailed written report to the Department within thirty (30) days (five [5] days for upsets and bypasses), unless requested earlier by the Department. The report shall contain a description of the noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

Compliance with these requirements does not relieve the Permittee from responsibility to maintain continuous compliance with the terms and conditions of this permit or the resulting liability for failure to comply.

S4. FACILITY LOADING

A. Design Criteria

Flows or waste loadings of the following design criteria for the permitted treatment facility shall not be exceeded:

Average flow for the maximum month: TBD

BOD₅ loading for maximum month: TBD

TSS loading for maximum month: TBD

B. Plans for Maintaining Adequate Capacity

When the actual flow or waste load reaches 85 percent of any one of the design criteria in S4.A for three (3) consecutive months, or when the projected increases would reach design capacity within five (5) years, whichever occurs first, the Permittee shall submit to the Department, a plan and a schedule for continuing to maintain capacity at the facility sufficient to achieve the effluent limitations and other conditions of this permit. This plan shall address any of the following actions or any others necessary to meet this objective.

1. Analysis of the present design including the introduction of any process modifications that would establish the ability of the existing facility to achieve the effluent limits and other requirements of this permit at specific levels in excess of the existing design criteria specified in paragraph A above.
2. Reduction or elimination of excessive infiltration and inflow of uncontaminated ground and surface water into the sewer system.
3. Limitation on future sewer extensions or connections or additional waste loads.
4. Modification or expansion of facilities necessary to accommodate increased flow or waste load.
5. Reduction of industrial or commercial flows or waste loads to allow for increasing sanitary flow or waste load.

Engineering documents associated with the plan must meet the requirements of WAC 173-240-060, "Engineering Report," and be approved by the Department

prior to any construction. The plan shall specify any contracts, ordinances, methods for financing, or other arrangements necessary to achieve this objective. In the event the Permittee intends to apply for State or Federal funding for the design or construction of a facility project, the plan must also meet the requirements of a "Facility Plan", as described in 40 CFR 32.2030.

C. Duty to Mitigate

The Permittee is required to take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit that has a reasonable likelihood of adversely affecting human health or the environment

D. Notification of New or Altered Sources

The Permittee shall submit written notice to the Department whenever any new discharge or a substantial change in volume or character of an existing discharge into the POTW is proposed which: (1) would interfere with the operation of, or exceed the design capacity of, any portion of the POTW; (2) is not part of an approved general sewer plan or approved plans and specifications; or (3) would be subject to pretreatment standards under 40 CFR Part 403 and Section 307(b) of the Clean Water Act. This notice shall include an evaluation of the POTW's ability to adequately transport and treat the added flow and/or waste load, the quality and volume of effluent to be discharged to the POTW, and the anticipated impact on the Permittee's effluent [40 CFR 122.42(b)].

E. Infiltration and Inflow Evaluation

1. The Permittee shall conduct an infiltration and inflow evaluation. Refer to the U.S. EPA publication, *I/I Analysis and Project Certification*, available as Publication No. 97-03 at: Publications Office, Department of Ecology, PO Box 47600, Olympia, WA, 98504-7600. Plant monitoring records may be used to assess measurable infiltration and inflow.
2. A report shall be prepared which summarizes any measurable infiltration and inflow. If infiltration and inflow have increased by more than fifteen (15) percent from that found in the previous analysis based on equivalent rainfall, the report shall contain a plan and a schedule for: (1) locating the sources of infiltration and inflow; and (2) correcting the problem. (The Permittee shall use the I/I analysis contained in the most recently approved *Facility Plan* as a basis for comparison.)
3. The report shall be submitted **with the next application for permit renewal.**

F. Wasteload Assessment

The Permittee shall conduct an assessment of flow and wasteload and submit a report to the Department **with the next application for permit renewal**. The report shall contain the following: an indication of compliance or noncompliance with the permit effluent limitations; a comparison between the existing and design monthly average dry weather and wet weather flows, peak flows, BOD, and total suspended solids loadings; and (except for the first report) the percentage increase in these parameters since the last report. (The Permittee shall use the analysis in the most recently approved *Facility Plan* for comparison.) The report shall also state the present and design population or population equivalent, projected population growth rate, and the estimated date upon which the design capacity is projected to be reached, according to the most restrictive of the parameters above.

S5. OPERATION AND MAINTENANCE

The Permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems, which are installed by a Permittee only when the operation is necessary to achieve compliance with the conditions of this permit.

A. Certified Operator

An operator certified for at least a Class III plant by the State of Washington shall be in responsible charge of the day-to-day operation of the wastewater treatment plant. An operator certified for at least a Class II plant shall be in charge during all regularly scheduled shifts.

B. O & M Program

The Permittee shall institute an adequate operation and maintenance program for their entire sewage system. Maintenance records shall be maintained on all major electrical and mechanical components of the treatment plant, as well as the sewage system and pumping stations. Such records shall clearly specify the frequency and type of maintenance recommended by the manufacturer and shall show the frequency and type of maintenance performed. These maintenance records shall be available for inspection at all times, consistent with the terms and conditions of General Condition G2 of this permit.

C. Short-term Reduction

If a Permittee contemplates a reduction in the level of treatment that would cause a violation of permit discharge limitations on a short-term basis for any reason, and such reduction cannot be avoided, the Permittee shall give written notification to the Department, if possible, thirty (30) days prior to such activities, detailing the reasons for, length of time of, and the potential effects of the reduced level of treatment. This notification does not relieve the Permittee of their obligations under this permit.

D. Electrical Power Failure

The Permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated wastes or wastes not treated in accordance with the requirements of this permit during electrical power failure at the treatment plant and/or sewage lift stations either by means of alternate power sources, standby generator, or retention of inadequately treated wastes. The Permittee shall maintain Reliability Class II (EPA 430-99-74-001) at the wastewater treatment plant, which requires primary sedimentation and disinfection.

E. Prevent Connection of Inflow

The Permittee shall strictly enforce their sewer ordinances and not allow the connection of inflow (roof drains, foundation drains, etc.) to the sanitary sewer system.

F. Bypass Procedures

Bypass, which is the intentional diversion of waste streams from any portion of a treatment facility, is prohibited, and the Department may take enforcement action against a Permittee for bypass unless one of the following circumstances (1, 2, or 3) is applicable.

1. Bypass for essential maintenance without the potential to cause violation of permit limits or conditions.

Bypass is authorized if it is for essential maintenance and does not have the potential to cause violations of limitations or other conditions of this permit, or adversely impact public health as determined by the Department prior to the bypass. The Permittee shall submit prior notice, if possible at least ten (10) days before the date of the bypass.

2. Bypass which is unavoidable, unanticipated and results in noncompliance of this permit.

This bypass is permitted only if:

- a. Bypass is unavoidable to prevent loss of life, personal injury, or severe property damage. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass.
- b. There are no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, stopping production, maintenance during normal periods of equipment downtime (but not if adequate backup equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance), or transport of untreated wastes to another treatment facility.
- c. The Department is properly notified of the bypass as required in Special Condition S3.E. of this permit.

3. Bypass which is anticipated and has the potential to result in noncompliance of this permit

The Permittee shall notify the Department at least thirty (30) days before the planned date of bypass. The notice shall contain: (1) a description of the bypass and its cause; (2) an analysis of all known alternatives which would eliminate, reduce, or mitigate the need for bypassing; (3) a cost-effectiveness analysis of alternatives including comparative resource damage assessment; (4) the minimum and maximum duration of bypass under each alternative; (5) a recommendation as to the preferred alternative for conducting the bypass; (6) the projected date of bypass initiation; (7) a statement of compliance with SEPA; (8) a request for modification of water quality standards as provided for in WAC 173-201A-110, if an exceedance of any water quality standard is anticipated; and (9) steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass.

For probable construction bypasses, the need to bypass is to be identified as early in the planning process as possible. The analysis required above shall be considered during preparation of the engineering report or facilities plan and plans and specifications and shall be included to the extent practical. In cases

where the probable need to bypass is determined early, continued analysis is necessary up to and including the construction period in an effort to minimize or eliminate the bypass.

The Department will consider the following prior to issuing an administrative order for this type bypass:

- a. If the bypass is necessary to perform construction or maintenance-related activities essential to meet the requirements of this permit.
- b. If there are feasible alternatives to bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, stopping production, maintenance during normal periods of equipment down time, or transport of untreated wastes to another treatment facility.
- c. If the bypass is planned and scheduled to minimize adverse effects on the public and the environment.

After consideration of the above and the adverse effects of the proposed bypass and any other relevant factors, the Department will approve or deny the request. The public shall be notified and given an opportunity to comment on bypass incidents of significant duration, to the extent feasible. Approval of a request to bypass will be by administrative order issued by the Department under RCW 90.48.120.

G. Operations and Maintenance Manual

The approved Operations and Maintenance Manual shall be kept available at the treatment plant and all operators shall follow the instructions and procedures of this manual.

An Operations and Maintenance (O&M) Manual shall be prepared by the Permittee in accordance with WAC 173-240-080 and be submitted to the Department for approval with the next application for permit renewal.

The O&M Manual shall include:

1. Emergency procedures for plant shutdown and cleanup in event of wastewater system upset or failure;
2. Plant maintenance procedures;
3. The treatment plant process control monitoring schedule;
4. Minimum staffing levels required to operate and maintain the treatment plant, and conduct sampling and analysis required by this permit and process control monitoring contained in the O&M Manual;

5. Operation and maintenance of all components of all treatment plant processes; and,
6. Operation and maintenance of sampling equipment used to demonstrate compliance with this permit.

S6. PRETREATMENT

A. General Requirements

The Permittee shall work with the Department to ensure that all existing and proposed commercial and industrial users of the publicly owned treatment works (POTW) are in compliance with the pretreatment regulations promulgated in 40 CFR Part 403 and any additional regulations that may be promulgated under Section 307(b) (pretreatment) and 308 (reporting) of the Federal Clean Water Act.

B. Wastewater Discharge Permit Required

The Permittee shall not allow significant industrial users (SIUs) to discharge wastewater to the Permittee's sewerage system until such user has received a wastewater discharge permit from the Department in accordance with Chapter 90.48 RCW and Chapter 173-216 WAC, as amended.

C. Identification and Reporting of Existing, New, and Proposed Industrial Users

1. The Permittee shall take continuous, routine measures to identify all new and proposed SIUs and potential significant industrial users (PSIUs) discharging or proposing to discharge to the Permittee's sewerage system (see Appendix B of Fact Sheet for definitions).
2. Within thirty (30) days of becoming aware of an unpermitted existing, new, or proposed industrial user who may be an SIU, the Permittee shall notify such user by registered mail that, if classified as an SIU, they shall be required to apply to the Department and obtain a State Waste Discharge Permit. A copy of this notification letter shall also be sent to the Department within this same 30-day period.
3. The Permittee shall also notify all PSIUs, as they are identified, that if their classification should change to an SIU, they shall be required to apply to the Department for a State Waste Discharge Permit within thirty (30) days of such change.

D. Duty to Enforce Discharge Prohibitions

1. In accordance with 40 CFR 403.5(a), the Permittee shall not authorize or knowingly allow the discharge of any pollutants into its POTW which cause pass through or interference, or which otherwise violates general or specific discharge prohibitions contained in 40 CFR Part 403.5 or WAC-173-216-060.
2. The Permittee shall not authorize or knowingly allow the introduction of any of the following into their treatment works:
 - a. Pollutants which create a fire or explosion hazard in the POTW (including, but not limited to waste streams with a closed cup flashpoint of less than 140 degrees Fahrenheit (°F) or 60 degrees Centigrade (°C) using the test methods specified in 40 CFR 261.21).
 - b. Pollutants which will cause corrosive structural damage to the POTW, but in no case discharges with pH lower than 5.0, or greater than 11.0 standard units, unless the works are specifically designed to accommodate such discharges.
 - c. Solid or viscous pollutants in amounts that could cause obstruction to the flow in sewers or otherwise interfere with the operation of the POTW.
 - d. Any pollutant, including oxygen demanding pollutants, (BOD, etc.) released in a discharge at a flow rate and/or pollutant concentration which will cause interference with the POTW.
 - e. Petroleum oil, nonbiodegradable cutting oil, or products of mineral origin in amounts that will cause interference or pass through.
 - f. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity which may cause acute worker health and safety problems.
 - g. Heat in amounts that will inhibit biological activity in the POTW resulting in interference but in no case heat in such quantities such that the temperature at the POTW headworks exceeds 40°C (104°F) unless the Department, upon request of the Permittee, approves, in writing, alternate temperature limits.
 - h. Any trucked or hauled pollutants, except at discharge points designated by the Permittee.
 - i. Wastewaters prohibited to be discharged to the POTW by the Dangerous Waste Regulations (Chapter 173-303 WAC), unless authorized under the Domestic Sewage Exclusion (WAC 173-303-071).

3. All of the following are prohibited from discharge to the POTW unless approved in writing by the Department under extraordinary circumstances (such as a lack of direct discharge alternatives due to combined sewer service or the need to augment sewage flows due to septic conditions):
 - a. Noncontact cooling water in significant volumes.
 - b. Stormwater, and other direct inflow sources.
 - c. Wastewaters significantly affecting system hydraulic loading, which do not require treatment, or would not be afforded a significant degree of treatment by the system.
4. The Permittee shall notify the Department if any industrial user violates the prohibitions listed in this section.

S7. RESIDUAL SOLIDS

The Permittee shall manage all residual solids (grit, screenings, scum, sludge and solid waste) in accordance with the requirements of: (1) RCW 90.48.080 and Water Quality Standards; (2) applicable sections of 40 CFR Part 503 and Chapter 173-308 WAC, "Biosolids Management"; (3) applicable sections of Chapter 173-304 WAC, "Minimum Functional Standards for Solid Waste Handling."

The final use and disposal of biosolids shall be done in accordance with Chapter 173-308 WAC ("Biosolids Management"), 40 CFR Part 503, and under coverage of the State general permit for biosolids management, as applicable.

S8. FACILITY PLAN

A. Final Facility Plan Submittal

By **April 15, 2003**, two copies of a final *Facility Plan* shall be prepared by the Permittee in accordance with WAC 173-240 and submitted to the Department for review and approval. The Permittee shall incorporate the following elements into the *Facility Plan*:

1. a *Capacity Analysis and Facility Reliability Report*;
2. a *Disinfection Report*;
3. SEPA or SERP determination;
4. sizing calculations and design criteria for each treatment process;
5. an *Inflow and Infiltration Evaluation*; and,
6. a comprehensive *Water Quality Evaluation*, including a characterization of the receiving water during irrigation and non-irrigation seasons, applicable water

quality standards, quantification of acute and chronic dilution factors, and how water quality standards will be met outside of any applicable dilution zone.

The report shall contain any appropriate requirements as described in the "Water Reclamation and Reuse Standards" (Washington State Department of Ecology and Department of Health, 1997). As required by RCW 90.48.112, the document must address the feasibility of using reclaimed water as defined in RCW 90.46.010. The Facility Plan shall include the City's final decision to proceed with either a land-based treatment option or plant upgrades.

THIS PAGE REVISED ON MARCH 25, 2003

B. Application for Project Funding

The Permittee shall apply for project engineering funding as soon as possible, but no later than **April 15, 2004**.

C. Plans and Specifications

By **January 15, 2005**, the Permittee shall submit to the Department for review and approval two (2) copies of approvable plans and specifications in accordance with WAC 173-240.

D. Application for Construction Funding

The Permittee shall apply for construction funding as soon as possible, but no later than **April 15, 2006**.

E. Status Report

The Permittee shall submit a report detailing the status of the facility improvement project, including but not limited to permitting, funding, construction, and environmental issues, to the Department and Waste Action Project by **April 15, 2006**.

F. Construction Quality Assurance Plan

Prior to the start of construction, the Permittee shall submit to the Department a quality assurance plan as required by WAC 173-240.

S9. SCHEDULE OF COMPLIANCE

Page 24 of 32

Permit No.: WA-002099-1

Expiration Date: July 31, 2007

By **April 15, 2007**, the Permittee shall be in compliance with the State's Surface Water Quality Standards for Chlorine, Ammonia, Fecal Coliform Bacteria, and Dissolved Oxygen.

THIS PAGE REVISED ON MARCH 25, 2003

GENERAL CONDITIONS

G1. SIGNATORY REQUIREMENTS

All applications, reports, or information submitted to the Department shall be signed and certified.

- A. All permit applications shall be signed by either a principal executive officer or a ranking elected official.
- B. All reports required by this permit and other information requested by the Department shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - 1. The authorization is made in writing by a person described above and submitted to the Department.
 - 2. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.)
- C. Changes to authorization. If an authorization under paragraph B.2 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph B.2 above must be submitted to the Department prior to or together with any reports, information, or applications to be signed by an authorized representative.
- D. Certification. Any person signing a document under this section shall make the following certification:

I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false

information, including the possibility of fine and imprisonment for knowing violations.

G2. RIGHT OF INSPECTION AND ENTRY

The Permittee shall allow an authorized representative of the Department, upon the presentation of credentials and such other documents as may be required by law:

- A. To enter upon the premises where a discharge is located or where any records must be kept under the terms and conditions of this permit.
- B. To have access to and copy - at reasonable times and at reasonable cost - any records required to be kept under the terms and conditions of this permit.
- C. To inspect - at reasonable times - any facilities, equipment (including monitoring and control equipment), practices, methods, or operations regulated or required under this permit.
- D. To sample or monitor - at reasonable times - any substances or parameters at any location for purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act.

G3. PERMIT ACTIONS

This permit may be modified, revoked and reissued, or terminated either at the request of any interested person (including the permittee) or upon the Department's initiative. However, the permit may only be modified, revoked and reissued, or terminated for the reasons specified in 40 CFR 122.62, 122.64 or WAC 173-220-150 according to the procedures of 40 CFR 124.5.

- A. The following are causes for terminating this permit during its term, or for denying a permit renewal application:
 - 1. Violation of any permit term or condition.
 - 2. Obtaining a permit by misrepresentation or failure to disclose all relevant facts.
 - 3. A material change in quantity or type of waste disposal.
 - 4. A determination that the permitted activity endangers human health or the environment, or contributes to water quality standards violations, and can only be regulated to acceptable levels by permit modification or termination [40 CFR part 122.64(3)].

5. A change in any condition that requires either a temporary or permanent reduction, or elimination of any discharge or sludge use or disposal practice controlled by the permit [40 CFR part 122.64(4)].
 6. Nonpayment of fees assessed pursuant to RCW 90.48.465.
 7. Failure or refusal of the permittee to allow entry as required in RCW 90.48.090.
- B. The following are causes for modification but not revocation and reissuance except when the permittee requests or agrees:
1. A material change in the condition of the waters of the State.
 2. New information not available at the time of permit issuance that would have justified the application of different permit conditions.
 3. Material and substantial alterations or additions to the permitted facility or activities which occurred after this permit issuance.
 4. Promulgation of new or amended standards or regulations having a direct bearing upon permit conditions, or requiring permit revision.
 5. The Permittee has requested a modification based on other rationale meeting the criteria of 40 CFR part 122.62.
 6. The Department has determined that good cause exists for modification of a compliance schedule, and the modification will not violate statutory deadlines.
 7. Incorporation of an approved local pretreatment program into a municipality's permit.
- C. The following are causes for modification or alternatively revocation and reissuance:
1. Cause exists for termination for reasons listed in A1 through A7 of this section, and the Department determines that modification or revocation and reissuance is appropriate.
 2. The Department has received notification of a proposed transfer of the permit. A permit may also be modified to reflect a transfer after the effective date of an automatic transfer (General Condition G8) but will not be revoked and reissued after the effective date of the transfer except upon the request of the new permittee.

G4. REPORTING A CAUSE FOR MODIFICATION

The Permittee shall submit a new application, or a supplement to the previous application, along with required engineering plans and reports whenever a material change to the facility or in the quantity or type of discharge is anticipated which is not specifically authorized by this permit. This application shall be submitted at least sixty (60) days prior to any proposed changes. The filing of a request by the Permittee for a

permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not relieve the Permittee of the duty to comply with the existing permit until it is modified or reissued.

G5. PLAN REVIEW REQUIRED

Prior to constructing or modifying any wastewater control facilities, an engineering report and detailed plans and specifications shall be submitted to the Department for approval in accordance with Chapter 173-240 WAC. Engineering reports, plans, and specifications shall be submitted at least one hundred eighty (180) days prior to the planned start of construction unless a shorter time is approved by Ecology. Facilities shall be constructed and operated in accordance with the approved plans.

G6. COMPLIANCE WITH OTHER LAWS AND STATUTES

Nothing in this permit shall be construed as excusing the Permittee from compliance with any applicable Federal, State, or local statutes, ordinances, or regulations.

G7. DUTY TO REAPPLY

The Permittee shall apply for permit renewal at least one (1) year prior to the specified expiration date of this permit.

G8. TRANSFER OF THIS PERMIT

In the event of any change in control or ownership of facilities from which the authorized discharge emanates, the Permittee shall notify the succeeding owner or controller of the existence of this permit by letter, a copy of which shall be forwarded to the Department.

A. Transfers by Modification

Except as provided in paragraph (B) below, this permit may be transferred by the Permittee to a new owner or operator only if this permit has been modified or revoked and reissued under 40 CFR 122.62(b)(2), or a minor modification made under 40 CFR 122.63(d), to identify the new Permittee and incorporate such other requirements as may be necessary under the Clean Water Act.

B. Automatic Transfers

This permit may be automatically transferred to a new Permittee if:

1. The Permittee notifies the Department at least 30 days in advance of the proposed transfer date.

2. The notice includes a written agreement between the existing and new Permittees containing a specific date transfer of permit responsibility, coverage, and liability between them.
3. The Department does not notify the existing Permittee and the proposed new Permittee of its intent to modify or revoke and reissue this permit. A modification under this subparagraph may also be minor modification under 40 CFR 122.63. If this notice is not received, the transfer is effective on the date specified in the written agreement.

G9. REDUCED PRODUCTION FOR COMPLIANCE

The Permittee, in order to maintain compliance with its permit, shall control production and/or all discharges upon reduction, loss, failure, or bypass of the treatment facility until the facility is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power of the treatment facility is reduced, lost, or fails.

G10. REMOVED SUBSTANCES

Collected screenings, grit, solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters shall not be resuspended or reintroduced to the final effluent stream for discharge to State waters.

G11. DUTY TO PROVIDE INFORMATION

The Permittee shall submit to the Department, within a reasonable time, all information which the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The Permittee shall also submit to the Department upon request, copies of records required to be kept by this permit [40 CFR 122.41(h)].

G12. OTHER REQUIREMENTS OF 40 CFR

All other requirements of 40 CFR 122.41 and 122.42 are incorporated in this permit by reference.

G13. ADDITIONAL MONITORING

The Department may establish specific monitoring requirements in addition to those contained in this permit by administrative order or permit modification.

G14. PAYMENT OF FEES

The Permittee shall submit payment of fees associated with this permit as assessed by the Department.

G15. PENALTIES FOR VIOLATING PERMIT CONDITIONS

Any person who is found guilty of willfully violating the terms and conditions of this permit shall be deemed guilty of a crime, and upon conviction thereof shall be punished by a fine of up to ten thousand dollars (\$10,000) and costs of prosecution, or by imprisonment in the discretion of the court. Each day upon which a willful violation occurs may be deemed a separate and additional violation.

Any person who violates the terms and conditions of a waste discharge permit shall incur, in addition to any other penalty as provided by law, a civil penalty in the amount of up to ten thousand dollars (\$10,000) for every such violation. Each and every such violation shall be a separate and distinct offense, and in case of a continuing violation, every day's continuance shall be deemed to be a separate and distinct violation.

G16. UPSET

Definition – “Upset” means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of the following paragraph are met.

A Permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

1) an upset occurred and that the Permittee can identify the cause(s) of the upset; 2) the permitted facility was being properly operated at the time of the upset; 3) the Permittee submitted notice of the upset as required in condition S3.E; and 4) the Permittee complied with any remedial measures required under S5. of this permit.

In any enforcement proceeding the Permittee seeking to establish the occurrence of an upset has the burden of proof.

G17. PROPERTY RIGHTS

This permit does not convey any property rights of any sort, or any exclusive privilege.

G18. DUTY TO COMPLY

The Permittee shall comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

G19. TOXIC POLLUTANTS

The Permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if this permit has not yet been modified to incorporate the requirement.

G20. PENALTIES FOR TAMPERING

The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than ten thousand dollars (\$10,000) per violation, or by imprisonment for not more than two years per violation, or by both. If a conviction of a person is for a violation committed after a first conviction of such person under this Condition, punishment shall be a fine of not more than twenty thousand dollars (\$20,000) per day of violation, or by imprisonment of not more than four (4) years, or by both.

G21. REPORTING PLANNED CHANGES

The Permittee shall, as soon as possible, give notice to the Department of planned physical alterations or additions to the permitted facility, production increases, or process modification which will result in: 1) the permitted facility being determined to be a new source pursuant to 40 CFR 122.29(b); 2) a significant change in the nature or an increase in quantity of pollutants discharged; or 3) a significant change in the Permittee's sludge use or disposal practices. Following such notice, this permit may be modified, or revoked and reissued pursuant to 40 CFR 122.62(a) to specify and limit any pollutants not previously limited. Until such modification is effective, any new or increased discharge in excess of permit limits or not specifically authorized by this permit constitutes a violation of the terms and conditions of this permit.

G22. REPORTING ANTICIPATED NON-COMPLIANCE

The Permittee shall give advance notice to the Department by submission of a new application or supplement thereto at least one hundred and eighty (180) days prior to commencement of such discharges, of any facility expansions, production increases, or other planned changes, such as process modifications, in the permitted facility or activity which may result in noncompliance with permit limits or conditions. Any maintenance of facilities, which might necessitate unavoidable interruption of operation and degradation of effluent quality, shall be scheduled during noncritical water quality periods and carried out in a manner approved by the Department.

G23. REPORTING OTHER INFORMATION

Where the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application, or in any report to the Department, it shall promptly submit such facts or information.

G24. COMPLIANCE SCHEDULES

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than fourteen (14) days following each schedule date.